

Office of The Chief Medical Officer, Ghaziabad

Ref.No. DSO/IDSP/2022/668

Dated 30/09/2022

PORTABLE WATER TEST REPORT

ADDRESS:- L.K INTERNATIONAL SCHOOL, NH-24, WAVE CITY ROAD, KAJIPURA, GHAZIABAD.

No of sample collected : 01

Date of sample collected : 29-09-2022

Sample collection area

Sample collection area	Sample ID	Result
L.K INTERNATIONAL SCHOOL, NH-24, WAVE CITY ROAD, KAJIPURA, GHAZIABAD.	622	Satisfactory

Test Result

H₂S Water test kit : Negative (-Ve) after 24-48 hrs incubation

Comments:-

H₂S water test kit report - ve reflects that water is free from Coliforms Organism.

Recommendation:

Given water sample safe for drinking purpose.

Lab Technician
IDSP Lab
Ghaziabad

Suruchi Saini
(Dr. Suruchi Saini)
Microbiologist IDSP Lab
Ghaziabad

ph
(Dr R.K Gupta)
District Public Health Expert
Ghaziabad

Abhodya
For L.K. International School

Dilans
Principal
L.K. International School

Office of The Chief Medical Officer, Ghaziabad


Ref.No: DSO/IDSP/2022/668

Dated 30-09-2022

Safe Drinking Water, Health & Hygiene Certificate

It is certified that a combined inspection team headed by Mr. Sujit Kumar Rai from IDSP UNIT, Ghaziabad and Nagar Nigam, Ghaziabad inspected the premises L.K INTERNATIONAL SCHOOL, NH-24, WAVE CITY ROAD, KAJIPURA, GHAZIABAD on 29-09-2022 and found L.K INTERNATIONAL SCHOOL, NH-24, WAVE CITY ROAD, KAJIPURA, GHAZIABAD has safe Drinking water facilities for the person is maintaining hygienic sanitation conditions in the water as per the norms. This certificate is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand canceled on proof.

Based on Ref: DSO/IDSP/2022/668



(Dr. R K Gupta)


District Public Health Expert

Ghaziabad


District Surveillance Officer
District Public Health Expert
District Ghaziabad

To

L.K INTERNATIONAL SCHOOL,
NH-24, WAVE CITY ROAD, KAJIPURA,
GHAZIABAD.


For L.K. International School

Secretary



Principal
L.K. International School
Affiliated to CBSE, New Delhi
Vide Code No. 2130905
Ghaziabad